




**Fire Test Report**

	<h2 style="text-align: center;">BHARAT TEST HOUSE</h2>	<small>ISO 9001:2000, ISO 14001:2004</small>
	<small>454/2, 1st. Floor, Timber Market, Near Azadpur Chowk, Delhi-110033</small>	
	<small>Tel.: 27672629, 27675696, 27675900 • Fax: 91-11-27681204</small>	
	<small>email : bharatsthouse@yahoo.com visit us at : www.bharatsthouse.com</small>	<small>QB100952, E9103044</small>
<p><b><u>TEST CERTIFICATE</u></b></p>		
<b>Test Certificate No.:</b> 20080619029	<b>Ref. No. :</b> Nil	
<b>Issue Date :</b> 19/06/08	<b>Date :</b> 03/06/08	
<b>Issued To :</b> M/s Avayo Electronics Canada Corp. E-13, Gate: 4, Ajman Free Zone, UAE.	<b>Job Order No. :</b> BTH/BM/080603/16	
	<b>Date of Sample Receipt :</b> 03/06/08	
	<b>Page ...1... of ...1...</b>	
<b>Sample Deposited By :</b> Party		
<b>Sample Particulars :</b> Sample of Avayo Calcium Sulphate Bare Panel.		
<p><b><u>S.No.</u></b>    <b><u>Test Conducted</u></b></p>	<p><b><u>Test Results</u></b></p>	<p><b><u>Test Method</u></b></p>
<p>1.    <b>Fire Test at 300°C For 2 hours</b></p>		<p>AS 15303 : 1989</p>
<p>Ignitability Spread of Flame Heat Evolved Smoke Evolved</p>	<p>Nil Nil Nil Less than 0.1</p>	
<p>..... <b>Remarks :-</b> With respect to the above tests the sample meets the requirements.</p>		
<p>Checked By</p>		<p style="text-align: center;">   <b>Authorised Signatory</b>  <b>(Rohit Gang)</b>  <b>Quality Manager</b> </p>
<p><small>(1) The above results are related only to the tests performed on the sample. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part &amp; can not be used as an evidence in the court of law &amp; should not be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 &amp; 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoiced amount (5) Report refers to the sample received by Bharat Test House unless mentioned otherwise.</small></p>		
<p><b>ISO 9001 : 2000 &amp; ISO 14001 : 2004 CERTIFIED ORGANISATION</b></p>		