



AVAYO ELECTRONICS CANADA CORPORATION

FLOORING RESISTANCE TEST

**AVAYO ELECTRONIC CANADA CORPORATION
NFPA 99 & ESD STM 7.1 Tests**

" Flooring Resistance " - Ohms
AVAYO CEMENTITIOUS PVC FINISH

600mm X 600mm X 35mm RAISED ACCESS FLOOR

12% RH, 720F 2/17/2012

Resistance: Point to Point on Single Tile (@100 Volts)

No Ground Provided

Panel 1	Panel 2	Panel 3
4.86 x 10 ⁹ Ω	5.05 x 10 ⁹ Ω	7.03 x 10 ⁹ Ω



Fowler

3551 Moore-Duncan Hwy.
Moore, SC 29369
Tel: 864-574-6415 Email:sfowler@sfowler.com

Stephen L. Fowler

The data and conclusions of this report are based upon the information and samples supplied to Fowler Associates for the tests described herein. Product users should make his or her own tests to determine the suitability of the information and conclusions herein stated or implied for their intended use, and shall assume all risk and liability in connection therein.